

ITEM: 6.6	REPORT SUMMARY MINOR VARIANCE APPLICATION FILE NUMBER A074/25
-----------	---

Report Date: August 15, 2025

THIS REPORT CONTAINS COMMENTS FROM THE FOLLOWING
DEPARTMENTS & AGENCIES (SEE SCHEDULE B):

Additional comments from departments and agencies received after the publication of the report will be made available on the City’s [website](#).

Internal Departments *Comments Received	Conditions Required		Nature of Comments
Committee of Adjustment	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	General Comments
Building Standards (Zoning)	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	General Comments
Development Planning	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	Recommend Approval/No Conditions
Development Engineering	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	General Comments
Forestry	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	General Comments w/Conditions
Development Finance	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	General Comments

External Agencies *Comments Received	Conditions Required		Nature of Comments *See Schedule B for full comments
Alectra	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	General Comments
Region of York	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	General Comments
TRCA	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	General Comments

PUBLIC & APPLICANT CORRESPONDENCE (SEE SCHEDULE C)				
All personal information collected because of this public meeting (including both written and oral submissions) is collected under the authority of the Municipal Act, the Municipal Freedom of Information and Protection of Privacy Act (MFIPPA), the Planning Act and all other relevant legislation, and will be used to assist in deciding on this matter. All personal information (as defined by MFIPPA), including (but not limited to) names, addresses, opinions and comments collected will become property of the City of Vaughan, will be made available for public disclosure (including being posted on the internet) and will be used to assist the Committee of Adjustment and staff to process this application.				
Correspondence Type	Name	Address	Date Received (mm/dd/yyyy)	Summary
Applicant			06/18/2025	Site Photos

BACKGROUND (SCHEDULE D, IF REQUIRED)	
* Background Information contains historical development approvals considered to be related to this file. This information should not be considered comprehensive.	
Application No. (City File)	Application Description (i.e. Minor Variance Application; Approved by COA / OLT)
N/A	N/A

ADJOURNMENT HISTORY	
* Previous hearing dates where this application was adjourned by the Committee and public notice issued.	
Hearing Date	Reason for Adjournment (to be obtained from NOD_ADJ)
N/A	N/A

SCHEDULES	
Schedule A	Drawings & Plans Submitted with the Application
Schedule B	Comments from Agencies, Building Standards & Development Planning
Schedule C (if required)	Public & Applicant Correspondence
Schedule D (if required)	Background

	MINOR VARIANCE APPLICATION FILE NUMBER A074/25
---	---

CITY WARD #:	3
APPLICANT:	Tanya Prefontaine & Michael Noel Prefontaine
AGENT:	Tanya Prefontaine
PROPERTY:	127 Antorisa Avenue, Woodbridge
ZONING DESIGNATION:	See below.
VAUGHAN OFFICIAL PLAN (2010) DESIGNATION:	Vaughan Official Plan 2010 ('VOP 2010'): "Low Rise Residential"
RELATED DEVELOPMENT APPLICATIONS:	N/A
PURPOSE OF APPLICATION:	Relief from the Zoning By-law is requested to permit the placement of an outdoor swimming pool with reduced setbacks to the rear and side lot lines, a wall-mounted air conditioner with increased encroachment into the side yard, a BBQ station with a reduced side yard setback, and a trellis located on the lot line.

The following variances have been requested from the City’s Zoning By-law:

The subject lands are zoned **R3, Third Density Residential Zone** and subject to the provisions of **Exception 14.1117** under **Zoning By-law 001-2021**, as amended.

#	Zoning By-law 001-2021	Variance requested
1	The minimum setback of an outdoor swimming pool to any lot line shall be 1.5m . [Section 4.21.3]	To permit a minimum setback of 1.0 m to the rear lot line for an outdoor swimming pool.
2	The minimum setback of an outdoor swimming pool to any lot line shall be 1.5m . [Section 4.21.3]	To permit a minimum setback of 1.0 m to the interior side lot line for an outdoor swimming pool.
3	A minimum distance of 0.6 m shall be required from any permitted encroachment to the nearest lot line. [Section 4.13.3]	To permit minimum distance of 0.4 m to the interior side lot line from the Air conditioner.
4	A wall mounted Air Conditioner is permitted to encroach a maximum 0.6 m into the minimum required interior side yard. [Section 4.13, Table 4-1]	To permit a wall mounted air conditioner to encroach a maximum 1.03 m into the required interior side yard.
5	A residential accessory structure shall be subject to the minimum interior side yard requirement for the principal building. A minimum interior side yard of 1.2 metres is required [Section 4.1.2.1.a, Table 4-1]	To permit a minimum interior side yard of 0.3 m for the residential accessory structure(Bbq station)
6	A residential accessory structure with a height greater than 2.8 m shall not be located closer than 2.4 m to any lot line. [Section 4.1.2.1.b]	To permit a residential accessory structure (trellis) with a height greater than 2.8 metres to be located a minimum 0.0 m from the interior side lot line.

HEARING INFORMATION
DATE OF MEETING: Thursday, August 21, 2025 TIME: 6:00 p.m. MEETING LOCATION: Vaughan City Hall, Woodbridge Room (2 nd Floor), 2141 Major Mackenzie Drive LIVE STREAM LINK: Vaughan.ca/LiveCouncil
PUBLIC PARTICIPATION
If you would like to speak to the Committee of Adjustment at the meeting, either remotely or in person, please complete the Request to Speak Form and submit to cofa@vaughan.ca

HEARING INFORMATION
<p>If you would like to submit written comments, please quote file number above and submit by mail or email to:</p> <p>Email: cofa@vaughan.ca</p> <p>Mail: City of Vaughan, Office of the City Clerk, Committee of Adjustment, 2141 Major Mackenzie Drive, Vaughan, ON, L6A 1T1</p> <p>To speak electronically, pre-registration is required by completing the Request to Speak Form on-line and submitting it to cofa@vaughan.ca no later than NOON on the last business day before the meeting.</p> <p>THE DEADLINE TO REGISTER TO SPEAK ELECTRONICALLY OR SUBMIT WRITTEN COMMENTS ON THE ABOVE NOTED FILE(S) IS NOON ON THE LAST BUSINESS DAY BEFORE THE MEETING.</p>

INTRODUCTION
<p>Staff and Agencies act as advisory bodies to the Committee of Adjustment. The comments contained in this report are presented as recommendations to the Committee.</p> <p>Section 45(1) of the Planning Act sets the criteria for authorizing minor variances to the City of Vaughan’s Zoning By-law. Accordingly, review of the application may consider the following:</p> <p>That the general intent and purpose of the by-law will be maintained. That the general intent and purpose of the official plan will be maintained. That the requested variance(s) is/are acceptable for the appropriate development of the subject lands. That the requested variance(s) is/are minor in nature.</p> <p>Public written and oral submissions relating to this application are taken into consideration by the Committee of Adjustment as part of its deliberations and final decision on this matter.</p>

COMMITTEE OF ADJUSTMENT	
Date Public Notice Mailed:	August 7, 2025
Date Applicant Confirmed Posting of Sign:	August 6, 2025
Applicant Justification for Variances: <small>*As provided in Application Form</small>	The backyard is very small and already has existing interlock. Moving the inground pool closer to the fence would allow for much less disruption of the existing interlock.
Was a Zoning Review Waiver (ZRW) Form submitted by Applicant: <small>*ZRW Form may be used by applicant in instances where a revised submission is made, and zoning staff do not have an opportunity to review and confirm variances prior to the issuance of public notice.</small>	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
COMMENTS:	
N/A	
Committee of Adjustment Recommended Conditions of Approval:	None

BUILDING STANDARDS (ZONING)	
**See Schedule B for Building Standards (Zoning) Comments	
Building Standards Recommended Conditions of Approval:	None

DEVELOPMENT PLANNING	
**See Schedule B for Development Planning Comments.	
Development Planning Recommended Conditions of Approval:	None

DEVELOPMENT ENGINEERING	
Link to Grading Permit Link to Pool Permit Link to Curb Curt Permit Link Culvert Installation	
<p>The Owner/Applicant shall submit an application and obtain an approved Pool Permit before initiating any work on the property. The Lot Grading Plan will be required for the Pool Permit Application. Please visit the Engineering Permits page of the City of Vaughan's website: Engineering Permits City of Vaughan to apply for a Grading Permit. For any inquiries regarding the Grading Permit, please</p>	

DEVELOPMENT ENGINEERING	
Link to Grading Permit Link to Pool Permit Link to Curb Curt Permit Link Culvert Installation	
email DEPermits@vaughan.ca The Development Engineering Department does not object to the Minor Variance application A074/25.	
Development Engineering Recommended Conditions of Approval:	None

PARKS, FORESTRY & HORTICULTURE (PFH)	
Recommended condition of approval listed below:	
PFH Recommended Conditions of Approval:	Install tree protection hoarding for the front city owned boulevard tree, 1.2m radius away from the trunk.

DEVELOPMENT FINANCE	
No comment no concerns.	
Development Finance Recommended Conditions of Approval:	None

BY-LAW AND COMPLIANCE, LICENSING AND PERMIT SERVICES	
No comments received to date.	
BCLPS Recommended Conditions of Approval:	None

BUILDING INSPECTION (SEPTIC)	
No comments received to date.	
Building Inspection Recommended Conditions of Approval:	None


FIRE DEPARTMENT	
No comments received to date.	
Fire Department Recommended Conditions of Approval:	None

RECOMMENDED CONDITIONS OF APPROVAL SUMMARY		
Should the Committee find it appropriate to approve this application in accordance with request and the sketch submitted with the application, as required by Ontario Regulation 200/96, the following conditions have been recommended:		
#	DEPARTMENT / AGENCY	CONDITION
1	Parks, Forestry and Horticulture Operations zachary.quizzetti@vaughan.ca	Install tree protection hoarding for the front city owned boulevard tree, 1.2m radius away from the trunk.
<i>All conditions of approval, unless otherwise stated, are considered to be incorporated into the approval “if required”. If a condition is no longer required after an approval is final and binding, the condition may be waived by the respective department or agency requesting conditional approval. A condition cannot be waived without written consent from the respective department or agency.</i>		

IMPORTANT INFORMATION
CONDITIONS: It is the responsibility of the owner/applicant and/or authorized agent to obtain and provide a clearance letter from respective department and/or agency (see condition chart above for contact). This letter must be provided to the Secretary-Treasurer to be finalized. All conditions must be cleared prior to the issuance of a Building Permit.


IMPORTANT INFORMATION	
<p>APPROVALS: Making any changes to your proposal after a decision has been made may impact the validity of the Committee’s decision.</p> <p>An approval obtained from the Committee of Adjustment, where applicable, is tied to the building envelope shown on the plans and drawings submitted with the application and subject to the variance approval.</p> <p>A building envelope is defined by the setbacks of the buildings and/or structures shown on the plans and drawings submitted with the application, as required by Ontario Regulation 200/96. Future development outside of an approved building envelope, where a minor variance was obtained, must comply with the provisions of the City’s Zoning By-law.</p> <p>Elevation drawings are provided to reflect the style of roof (i.e. flat, mansard, gable etc.) to which a building height variance has been applied. Where a height variance is approved, building height is applied to the style of roof (as defined in the City’s Zoning By-law) shown on the elevation plans submitted with the application.</p> <p>Architectural design features that are not regulated by the City’s Zoning By-law are not to be considered part of an approval unless specified in the Committee’s decision.</p>	
<p>DEVELOPMENT CHARGES: That the payment of the Regional Development Charge, if required, is payable to the City of Vaughan before issuance of a building permit in accordance with the Development Charges Act and the Regional Development Charges By-law in effect at the time of payment.</p> <p>That the payment of the City Development Charge, if required, is payable to the City of Vaughan before issuance of a building permit in accordance with the Development Charges Act and the City's Development Charges By-law in effect at the time of payment.</p> <p>That the payment of the Education Development Charge if required, is payable to the City of Vaughan before issuance of a building permit in accordance with the Development Charges Act and the Boards of Education By-laws in effect at the time of payment</p> <p>That the payment of Special Area Development charge, if required, is payable to the City of Vaughan before issuance of a building permit in accordance with the Development Charges Act and The City's Development Charge By-law in effect at the time of Building permit issuance to the satisfaction of the Reserves/Capital Department.</p>	
<p>NOTICE OF DECISION: If you wish to be notified of the decision in respect to this application or a related Ontario Land Tribunal (OLT) hearing you must complete a Request for Decision form and submit to the Secretary Treasurer (ask staff for details). In the absence of a written request to be notified of the Committee’s decision you will not receive notice.</p>	

SCHEDULE A: DRAWINGS & PLANS



RECEIVED

By russog at 11:40 am, Jul 15, 2025



0.0 m setback
distance from top of
trellis to property line

Portion of top of
trellis to be removed
to provide 0.15 m
setback distance to
property line

Existing
Fence

measured from
groundlevel (not from
top of pavement)

113"

0.15m setback
distance from edge of
post to edge of fence





Photo of existing trellis

Trellis Detail

127 Antorisa Avenue

Setbacks to Property Line :

← 3.3 metres to west property line
↑ 0.3 metres to north property line



SCHEDULE B:
COMMENTS FROM AGENCIES, BUILDING STANDARDS &
DEVELOPMENT PLANNING

Internal Departments *Comments Received	Conditions Required		Nature of Comments
Building Standards (Zoning)	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	General Comments
Development Planning	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	Recommend Approval/No Conditions

External Agencies *Comments Received	Conditions Required		Nature of Comments *See Schedule B for full comments
Alectra	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	General Comments
Region of York	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	General Comments
TRCA	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	General Comments

Date: July 24th 2025

Attention: **Gregory Seganfreddo**

RE: Request for Comments

File No.: **A074-25**

Related Files:

Applicant Tanya Prefontaine

Location 127 Antorisa Avenue

COMMENTS:

- ☐

We have reviewed the proposed Variance Application and have no comments or objections to its approval.
- ☒

We have reviewed the proposed Variance Application and have no objections to its approval, subject to the following comments (attached below).
- ☐

We have reviewed the proposed Variance Application and have the following concerns (attached below).

Alectra Utilities (formerly PowerStream) has received and reviewed the proposed Variance Application. This review, however, does not imply any approval of the project or plan.

All proposed billboards, signs, and other structures associated with the project or plan must maintain minimum clearances to the existing overhead or underground electrical distribution system as specified by the applicable standards, codes and acts referenced.

In the event that construction commences, and the clearance between any component of the work/structure and the adjacent existing overhead and underground electrical distribution system violates the Occupational Health and Safety Act, the customer will be responsible for 100% of the costs associated with Alectra making the work area safe. All construction work will be required to stop until the safe limits of approach can be established.

In the event construction is completed, and the clearance between the constructed structure and the adjacent existing overhead and underground electrical distribution system violates the any of applicable standards, acts or codes referenced, the customer will be responsible for 100% of Alectra’s cost for any relocation work.

References:

- Ontario Electrical Safety Code, latest edition (Clearance of Conductors from Buildings)
- Ontario Health and Safety Act, latest edition (Construction Protection)
- Ontario Building Code, latest edition (Clearance to Buildings)
- PowerStream(Construction Standard 03-1, 03-4, 03-9), attached
- Canadian Standards Association, latest edition (Basic Clearances)

If more information is required, please contact either of the following:

Stephen Cranley, C.E.T

Mitchell Penner


Supervisor, Distribution Design, ICI & Layouts (North)
Phone: 1-877-963-6900 ext. 31297

Supervisor, Distribution Design-Subdivisions
Phone: 416-302-6215

E-mail: stephen.cranley@alectrautilities.com

Email: Mitchell.Penner@alectrautilities.com

LOCATION OF WIRES, CABLES OR CONDUCTORS	SYSTEM VOLTAGE			
	SPAN GUYS AND COMMUNICATIONS WIRES	UP TO 600V AND NEUTRAL	4.16/2.4kV TO 27.6/16kV (SEE NOTE 1)	44kV
	MINIMUM VERTICAL CLEARANCES (SEE NOTE 2)			
OVER OR ALONGSIDE ROADS, DRIVEWAYS OR LANDS ACCESSIBLE TO VEHICLES	442cm	442cm	480cm	520cm
OVER GROUND ACCESSIBLE TO PEDESTRIANS AND BICYCLES ONLY	250cm	310cm	340cm	370cm
ABOVE TOP OF RAIL AT RAILWAY CROSSINGS	730cm	730cm	760cm	810cm



MINIMUM ATTACHMENT HEIGHT = MAXIMUM SAG
 + MINIMUM VERTICAL CLEARANCE (FROM ABOVE TABLE)
 + GRADE DIFFERENCE
 + 0.3m (VEHICLE OR RAILWAY LOCATION)
 + SNOW DEPTH (PEDESTRIAN LOCATION, SEE NOTE 3)

NOTES:

1. THE MULTIGROUNDED SYSTEM NEUTRAL HAS THE SAME CLEARANCE AS THE 600V SYSTEM.
2. THE VERTICAL CLEARANCES IN THE ABOVE TABLE ARE UNDER MAXIMUM SAG CONDITIONS.
3. REFER TO CSA STANDARD C22.3 No.1, ANNEX D FOR LOCAL SNOW DEPTH VALUES.
4. ALL CLEARANCES ARE IN ACCORDANCE TO CSA STANDARD C22.3.

CONVERSION TABLE

METRIC	IMPERIAL (APPROX)
810cm	27'-0"
760cm	25'-4"
730cm	24'-4"
520cm	17'-4"
480cm	16'-0"
442cm	15'-5"
370cm	12'-4"
340cm	11'-4"
310cm	10'-4"
250cm	8'-4"

MINIMUM VERTICAL CLEARANCES OF WIRES, CABLES AND CONDUCTORS ABOVE GROUND OR RAILS

ORIGINAL ISSUE DATE: 2010-DEC-24 REVISION NO: R1 REVISION DATE: 2012-JAN-09

REFERENCES

SAGS AND TENSIONS | SECTION 02


Certificate of Approval

This construction Standard meets the safety requirements of Section 4 of Regulation 22/04

Joe Crozier, P.Eng. 2012-JAN-09

Name Date

P.Eng. Approval By: Joe Crozier



VOLTAGE	MINIMUM HORIZONTAL CLEARNACE UNDER MAXIMUM SWING CONDITIONS DIMENSION "X" (SEE NOTES 1, 3 & 4)	MINIMUM VERTICAL CLEARANCE UNDER MAXIMUM DESIGN SAG CONDITIONS DIMENSION "Y" (SEE NOTES 1, 2, 4 & 5)
0-600V AND NEUTRAL	100cm	250cm
4.16/2.4 TO 44kV	300cm	480cm

NOTES

1. UNDER NO CIRCUMSTANCES SHALL A CONDUCTOR BE PERMITTED TO PENETRATE THE ENVELOPE SHOWN BY THE DOTTED LINE.
2. THE VERTICAL CLEARANCES ARE UNDER CONDITIONS OF MAXIMUM DESIGN SAG.
3. THE HORIZONTAL CLEARANCES ARE UNDER CONDITIONS OF MAXIMUM SWING. WHERE THE CONDUCTOR SWING IS NOT KNOWN A HORIZONTAL CLEARANCE OF 480CM SHALL BE USED.
4. BUILDINGS THAT EXCEED 3 STOREYS OR 15M IN HEIGHT, THE MINIMUM HORIZONTAL CLEARANCE OF THE SECONDARY CONDUCTORS SHOULD BE INCREASED TO 300cm WHERE IT IS NECESSARY TO ALLOW FOR THE RAISING OF LADDERS BY LOCAL FIRE DEPARTMENTS.
5. IN SITUATIONS SUCH AS MULTI-LEVEL GARAGES, WHERE ROOFS ARE NORMALLY USED BY PERSONS AND VEHICLES, THE VERTICAL CLEARANCES OF POWERSTREAM STANDARD 03-1 SHALL APPLY.
6. DISTRIBUTION LINES CONSTRUCTED NEAR BUILDINGS SHALL BE BUILT TO AVOID OVERHANG WHEREVER POSSIBLE. WHERE LINES MUST BE CONSTRUCTED OVER OR ADJACENT TO BUILDINGS THE APPLICABLE HORIZONTAL AND VERTICAL CLEARANCES SHALL BE AT CONDITIONS OF MAXIMUM CONDUCTOR SWING AND MAXIMUM SAG. THE ABOVE CLEARANCES ARE DESIGNED TO PREVENT PERSONS ON OR IN BUILDINGS AS WELL AS EXTERNAL MACHINERY USED IN CONJUNCTION WITH A BUILDING TO COME IN CONTACT WITH CONDUCTORS. EFFORTS SHOULD BE MADE TO INCREASE THESE CLEARANCES WHERE POSSIBLE.
7. ALL CLEARANCES ARE IN ACCORDANCE TO CSA C22.3 NO.1-06 (TABLE-9).


CONVERSION TABLE	
METRIC	IMPERIAL (APPROX)
480cm	16'-0"
300cm	10'-0"
250cm	8'-4"
100cm	3'-4"

**MINIMUM VERTICAL & HORIZONTAL CLEARANCES
OF CONDUCTORS FROM BUILDINGS OR OTHER
PERMANENT STRUCTURES (CONDUCTORS NOT
ATTACHED TO BUILDINGS)**

ORIGINAL ISSUE DATE: 2010-MAY-05 REVISION NO: REVISION DATE:

Certificate of Approval	
This construction Standard meets the safety requirements of Section 4 of Regulation 22/04	
Debbie Dadwani, P.Eng.	2010-MAY-05
Name	Date
P.Eng. Approval By: <u>D. Dadwani</u>	

PS:\System Planning and Standards\Standard Design\PowerStream Standards\PowerStream Standards working folder\Section 2-3-4\DWG 03-4 R0 May 5, 2010.dwg, 5/5/2010 9:27:02 AM, Adobe PDF



NOTES:

1. ANY STRUCTURE WITHIN 5.0 METRES OF POOL EDGE SHALL BE CONSIDERED PART OF THE POOL.
2. THERE SHALL NOT BE ANY OVERHEAD SECONDARY OR COMMUNICATION WIRING (750V OR LESS) ABOVE THE POOL, AND ABOVE OTHER ELEVATED SURFACES ASSOCIATED WITH THE POOL, INCLUDING BUT NOT RESTRICTED TO A DIVING STRUCTURE, SLIDE, SWINGS, OBSERVATION STAND, TOWER OR PLATFORM, OR ABOVE THE ADJACENT AREA EXTENDING 5.0M HORIZONTALLY FROM THE POOL EDGE.
3. THERE SHALL NOT BE ANY OVERHEAD PRIMARY WIRING (751V - 44KV) ABOVE THE POOL AND OTHER ELEVATED SURFACES ASSOCIATED WITH THE POOL, OR ABOVE THE ADJACENT AREA EXTENDING 7.5M HORIZONTALLY FROM THE POOL EDGE.
4. ANY UNDERGROUND CONDUCTORS SHALL BE 2.0M AWAY FROM POOL EDGE IN DUCT WITH NON-CONDUCTING JACKET. FOR DEPTH AND DUCT DETAILS REFER TO FIGURE 3 IN 25-100 FOR 200A SERVICE AND 25-101 FOR 400A SERVICE RESPECTIVELY, AS PER POWERSTREAM SERVICE DESIGN SPECIFICATIONS.
5. THESE DIMENSIONS APPLY TO ALL SIDES OF THE POOL.

CONVERSION TABLE	
METRIC	IMPERIAL (APPROX.)
7.5m	24'-6"
5.0m	16'-3"
2.0m	6'-6"

REFERENCES

FIGURE 3, 25-100	SECTION 25
FIGURE 3, 25-101	SECTION 25

**MINIMUM CLEARANCES FOR
CONDUCTORS ADJACENT
TO SWIMMING POOLS**

ORIGINAL ISSUE DATE: 2013-JUNE-12 REVISION NO: R0 REVISION DATE:

Certificate of Approval	
This construction Standard meets the safety requirements of Section 4 of Regulation 22/04	
Joe Crozier, P.Eng.	2013-JUN-12
Name	Date
P.Eng. Approval By:	Joe Crozier

To: Committee of Adjustment

From: Gregory Seganfreddo, Building Standards Department

Date: July 22, 2025

Applicant: Tanya Prefontaine

Location: 127 Antorisa Avenue
PLAN 65M4291 Lot 177

File No.(s): A074/25

Zoning Classification:

The subject lands are zoned R3, Third Density Residential Zone and subject to the provisions of Exception 14.1117 under Zoning By-law 001-2021, as amended.

#	Zoning By-law 001-2021	Variance requested
1	The minimum setback of an outdoor swimming pool to any lot line shall be 1.5m . [Section 4.21.3]	To permit a minimum setback of 1.0 m to the rear lot line for an outdoor swimming pool.
2	The minimum setback of an outdoor swimming pool to any lot line shall be 1.5m . [Section 4.21.3]	To permit a minimum setback of 1.0 m to the interior side lot line for an outdoor swimming pool.
3	A minimum distance of 0.6 m shall be required from any permitted encroachment to the nearest lot line. [Section 4.13.3]	To permit minimum distance of 0.4 m to the interior side lot line from the Air conditioner.
4	A wall mounted Air Conditioner is permitted to encroach a maximum 0.6 m into the minimum required interior side yard. [Section 4.13, Table 4-1]	To permit a wall mounted air conditioner to encroach a maximum 1.03 m into the required interior side yard.
5	A residential accessory structure shall be subject to the minimum interior side yard requirement for the principal building. A minimum interior side yard of 1.2 metres is required [Section 4.1.2.1.a, Table 4-1]	To permit a minimum interior side yard of 0.3 m for the residential accessory structure (Bbq station).
6	A residential accessory structure with a height greater than 2.8 m shall not be located closer than 2.4 m to any lot line. [Section 4.1.2.1.b]	To permit a residential accessory structure (trellis) with a height greater than 2.8 metres to be located a minimum 0.0 m from the interior side lot line.

Staff Comments:

Stop Work Order(s) and Order(s) to Comply:

There are no outstanding Orders on file

Building Permit(s) Issued:

A Building Permit has not been issued. The Ontario Building Code requires a building permit for structures that exceed 10m2

Other Comments:

General Comments	
1	The applicant shall be advised that additional variances may be required upon review of detailed drawing for building permit/site plan approval.

Conditions of Approval:

If the committee finds merit in the application, the following conditions of approval are recommended.

* Comments are based on the review of documentation supplied with this application.

From: [Zachary Guizzetti](#)
To: [Committee of Adjustment Mailbox](#)
Subject: A074/25 Vaughan - Forestry - Complete With Conditions (Gianluca Russo)
Date: July-25-25 2:38:54 PM

Please note that Vaughan - Forestry process is now complete for a COA folder with the following details:

File No: A074/25

Type: Minor Variance - Minor Type 1

Address: 127 Antorisa Ave

Comments:

Conditions: Install tree protection hoarding for the front city owned boulevard tree, 1.2m radius away from the trunk.

To: Christine Vigneault, Committee of Adjustment Secretary Treasurer

From: Nancy Tuckett, Director of Development and Parks Planning

Date: August 13, 2025

Name of Owner: Tanya Prefontaine

Location: 127 Antorisa Avenue

File No.(s): A074/25

Proposed Variance(s):

1. To permit a minimum setback of **1.0 m** to the rear lot line for an outdoor swimming pool.
2. To permit a minimum setback of **1.0 m** to the interior side lot line for an outdoor swimming pool.
3. To permit minimum distance of **0.4 m** to the interior side lot line from the Air conditioner.
4. To permit a wall mounted air conditioner to encroach a maximum **1.03 m** into the required interior side yard.
5. To permit a minimum interior side yard of **0.3 m** for the residential accessory structure (Bbq station).
6. To permit a residential accessory structure (trellis) with a height greater than 2.8 m to be located a minimum **0.15 m** from the interior side lot line.

By-Law 001-2021 Requirement(s):

1. The minimum setback of an outdoor swimming pool to any lot line shall be **1.5 m**.
2. The minimum setback of an outdoor swimming pool to any lot line shall be **1.5 m**.
3. A minimum distance of **0.6 m** shall be required from any permitted encroachment to the nearest lot line.
4. A wall mounted Air Conditioner is permitted to encroach a maximum **0.6 m** into the minimum required interior side yard.
5. A residential accessory structure shall be subject to the minimum interior side yard requirement for the principal building. A minimum interior side yard of **1.2 m** is required.
6. A residential accessory structure with a height greater than 2.8 m shall not be located closer than **2.4 m** to any lot line.

Official Plan:

Vaughan Official Plan 2010 ('VOP 2010'): "Low Rise Residential".

Comments:

The Owners are seeking relief to permit a pool, an outdoor BBQ island, and a trellis in the rear yard, as well as a wall mounted AC unit in the north interior side lot line.

The Development and Parks Planning Department has no objections to Variances 1 and 2 to reduce the minimum setback of the proposed swimming pool to the rear and southern interior side lot lines. The proposed setback of the pool is sufficient for access and maintenance. The areas between the pool and the lot lines are proposed to be sodded, and a 1.8 m-tall wood fence exists along the southern and rear lot lines to provide buffering. The proposed setback reductions to the pool are not anticipated to incur any negative stormwater management or privacy impacts on neighbouring properties.

The Development and Parks Planning Department has no objections to Variances 3 and 4 to reduce the minimum required setback for the wall-mounted air conditioner (AC) unit in the northern interior side yard. Unobstructed access between the front and rear yards can be provided through the southern interior side yard. The proposed 0.47 m setback between the AC unit and the northern lot line is sufficient for maintenance.

The Development and Parks Planning Department has no objections to Variances 5 and 6 to permit reduced setbacks to a proposed outdoor BBQ island and a trellis. The proposed outdoor BBQ island is setback 0.3 m from the northern interior side lot line and is 0.9 m in height. The BBQ island is not anticipated to have any visual impacts on the adjacent

neighbour. The proposed trellis is located between the BBQ island and the northern interior side lot line. The proposed trellis is 2.87 m in height and is supported by two wood columns. The proposed trellis has an open and minimal mass and is not anticipated to incur visual impacts on the adjacent property. Development Engineering staff have reviewed the proposed setback reductions and have no concerns regarding their impacts on stormwater runoff.

Accordingly, the Development and Parks Planning Department supports the requested variance and is of the opinion that the proposal is minor in nature, maintains the general intent and purpose of the Official Plan and Zoning By-law, and is desirable for the appropriate development of the land.

Recommendation:

The Development and Parks Planning Department recommends approval of the application.

Conditions of Approval:

If the Committee finds merit in the application, the following conditions of approval are recommended:

None

Comments Prepared by:

Harry Zhao, Planner

Janany Nagulan, Senior Planner

From: [Cameron McDonald](#)
To: [Committee of Adjustment Mailbox](#)
Subject: [External] RE: A074/25 (127 Antorisa Avenue) - REQUEST FOR COMMENTS, CITY OF VAUGHAN
Date: Tuesday, July 29, 2025 9:38:19 AM

CAUTION! This is an external email. Verify the sender's email address and carefully examine any links or attachments before clicking. If you believe this may be a phishing email, please use the Phish Alert Button.

Hello,

Based on a review of our screening mapping, I can confirm that the subject property is not located within TRCA's Regulated Area. As such, any site alteration or development on the property would not require a permit from the TRCA.

Based on the above, we have no comments/requirements.

Regards,

Cameron McDonald

Planner I

Development Planning and Permits | Development and Engineering Services

T: [\(437\) 880-1925](tel:(437)880-1925)

E: cameron.mcdonald@trca.ca

A: [5 Shoreham Drive, Toronto, ON, M3N 1S4](#) | trca.ca



From: [Development Services](#)
To: [Committee of Adjustment Mailbox](#)
Subject: [External] RE: A074/25 (127 Antorisa Avenue) - REQUEST FOR COMMENTS, CITY OF VAUGHAN
Date: July-25-25 3:40:36 PM

CAUTION! This is an external email. Verify the sender's email address and carefully examine any links or attachments before clicking. If you believe this may be a phishing email, please use the Phish Alert Button.

Good afternoon,

The Regional Municipality of York has completed its review of the above minor variance and has no comment.

Regards,

Gabrielle Hurst MCIP, RPP

Associate Planner, Development Planning, Economic and Development Services Branch
Corporate Services Department

The Regional Municipality of York | 17250 Yonge Street | Newmarket, ON L3Y 8V3


O: 905-830-4444 ext. 71538 | developmentservices@york.ca |

Our Mission: **Working together to serve our thriving communities – today and tomorrow**


For more information check us out at www.york.ca/developmentservices

SCHEDULE C: PUBLIC & APPLICANT CORRESPONDENCE

Correspondence Type	Name	Address	Date Received (mm/dd/yyyy)	Summary
Applicant			06/18/2025	Site Photos







4 inch
post

solar
lights

4 inch
post

Privacy
Screen

2.6 m total height from ground
height

SCHEDULE D: BACKGROUND

Application No. (City File)	Application Description (i.e. Minor Variance Application; Approved by COA / OLT)
N/A	N/A