

MacPherson, Adriana

Subject: FW: A106/20

From: Khan, Farzana <Farzana.Khan@vaughan.ca>
Sent: December-01-20 3:05 PM
To: MacPherson, Adriana <Adriana.MacPherson@vaughan.ca>
Cc: Vigneault, Christine <Christine.Vigneault@vaughan.ca>
Subject: RE: A106/20

Hi Adriana,

Yes, I have updated the comment. Here it is

DE comments:

The Development Engineering (DE) Department does not object to variance application A106/20.

The space inside the garage cannot be considered as a parking space, as the length of the parking garage was reduced to 5.17m whereas the by law required length is 6m.

However, this property meets the bylaw requirements by providing two parking spaces in the driveway.

Regards,

Farzana Khan
Development Engineering Reviewer
905-832-8585 ext. 3608 | farzana.khan@Vaughan.ca

City of Vaughan | Development Engineering Department
2141 Major Mackenzie Dr., Vaughan, ON L6A 1T1
vaughan.ca

